



Certificate of Compliance

Certificate: 2433875

Master Contract: 253122

Project: 70018309

Date Issued: December 20, 2014

Issued to: Castagra Products Inc.
5190 Neil Rd, Suite 430
Reno, NV 89502-8535
USA
Attention: Peter P. Roosen

The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US'



C US

Drinking Water
NSF/ANSI 61

Thomas Valente

Issued by: Thomas Valente

PRODUCTS

CLASS 6861 05 - BARRIER MATERIALS - NSF/ANSI 61 SECTION 5 - Certified to NSF/ANSI 61

Materials in contact with Drinking Water (Cold 23°C)

Storage Water Tank Applications*:

- Ecodur 201

*Note: When used as a coating for potable water storage tanks, the tank size shall be 5 gallons or greater.

Piping System Applications:**

- Ecodur 201

**Note: When used as a coating for potable water pipes, the nominal pipe diameter shall be 4" or greater.

APPLICABLE REQUIREMENTS

NSF/ANSI - 61 - 2014 - Drinking Water System Components